
Effluent Disposal

The permit authorizes treated effluent from the WWTP to be discharged to a 0.025 MGD AADF permitted capacity slow-rate restricted public access system which consists of:

1. R – 001: One 0.5 acre percolation pond acre that is permitted for 0.0064 MGD (AADF) rapid infiltration basin
 2. R – 002: One spray field with a total wetted area of 2.0 acres located on 3rd Street, south of SR 40 and Butler Street approximately $\frac{3}{4}$ miles southeast of the WWTP.
-