
WEST CITRUS SERVICE AREA



West Citrus WTP is located at 6282 W. Grant Street, Homosassa FL. The plant serves approximately 62 customers.

Water System Summary

The design capacity for the plant is 0.072 MGD. . The WTP is permitted by the FDEP (Category V Class D) under Potable Water System (PWS) identification number 6094656.

Water System Components

- Distribution system has approximately
 - 4,970 LF of 2 inch PVC pipe
 - (1) Automatic Flush Valve (AFV)
 - 0 fire hydrants.
 - One (1) public potable water supply well
 - One (1) Submersible well pump
 - Water is disinfected by liquid chlorination before it enters the hydro-pneumatic tank
 - One (1) 1,000 gallon hydro-pneumatic (HPN) tank
-